

| | | | | | | | | | |
|--|--|--|--|--|--|--|--|--|--|
| | | | | | | | | | |
|--|--|--|--|--|--|--|--|--|--|

B.TECH.
(SEM V) THEORY EXAMINATION 2018-19
POWER SYSTEM OPTIMIZATION

Time: 3 Hours

Total Marks: 70

Note: 1. Attempt all Sections. If require any missing data; then choose suitably.

SECTION A

1. Attempt all questions in brief. 2 x 7 = 14
- What do you understand by optimization? Write any two application of optimization in electrical engineering field.
 - Under what condition is the solution of LPP; 1-Unbound 2-Infinite?
 - Derive and explain the significance of the golden mean ratio.
 - What is the basic difference between DFP and BFGS methods?
 - What is a multistage decision problem?
 - Define genetic algorithm.
 - What do you understand by economic dispatch problem?

SECTION B

2. Attempt any three of the following: 3 x 7 = 21
- Mention the rules for primal-dual conversion and using it write the dual of the following LPP
 minimize $Z=3x_1+7x_2+4x_3$
 subject to
 $4x_1+5x_2+x_3 \geq 9$
 $2x_1+3x_2+2x_3 \geq 7$
 $2x_1+4x_2+6x_3 \geq 12$
 $5x_1+5x_2+2x_3 \geq 10$ x_1, x_2, x_3 all are ≥ 0
 - Find the number of experiments to obtain a value of $L_n/L_0=0.001$ for (a) Fibonacci method (b) interval halving method (c) exhaustive search.
 - What are the similarities and differences between the traditional methods and genetic algorithm
 - How is the final value problem converted into an initial value problem? Also draw the block diagram representation of both the types of problem.
 - A constant load of 300 MW is supplied by two 200 MW generators, 1 and 2, for which the respective incremental fuel costs are
 $dC_1/dP_{G1}=0.10P_{G1}+20$
 $dC_2/dP_{G2}=0.12P_{G2}+15$
 with powers P_G in MW and costs C in Rs/hr. Determine (a) the most economical division of load between the generators and (b) the saving in Rs/day thereby obtained compared to equal load sharing between machines.

SECTION C

- 3. Attempt any one part of the following: 7 x 1 = 7**
- (a) Use the Simplex method to find the maximum value of
 $Z = 2x_1 - x_2 + 2x_3$
s. t
 $2x_1 + x_2 \leq 10$
 $x_1 + 2x_2 - 2x_3 \leq 20$
 $x_2 + 2x_3 \leq 5$
 $x_1, x_2, x_3 \geq 0$
- (b) Solve using dual simplex method
Minimize $f = 20x_1 + 16x_2$
Subject to
 $x_1 \geq 2.5$
 $x_2 \geq 6$
 $2x_1 + x_2 \geq 17$
 $x_1 + x_2 \geq 12$
 $x_i \geq 0 \quad i=1,2$
- 4. Attempt any one part of the following: 7 x 1 = 7**
- (a) Find the minimum of $f = x(x-1.5)$ in the interval (0, 1) to within 10% of the exact value using dichotomous method (use $\delta = 0.001$).
- (b) How is interior penalty function method different from exterior penalty function method?
- 5. Attempt any one part of the following: 7 x 1 = 7**
- (a) Explain the concept of sub-optimization and principle of optimality.
- (b) Represent a multistage decision problem; explain the terms associated with it. What are the different types of multistage decision problems?
- 6. Attempt any one part of the following: 7 x 1 = 7**
- (a) What are the various types of GA operators, explain each in detail. Draw the flow chart for accomplishing GA.
- (b) How is GA used in solving global optimization problem?
- 7. Attempt any one part of the following: 7 x 1 = 7**
- (a) Explain the optimal generator scheduling for the thermal units when losses are considered. Also explain ITL and penalty factor and write the algorithm for the same.
- (b) What is the difference in the optimal scheduling of thermal and hydro thermal units and how is it accomplished in the hydrothermal unit?